



E A S T E R N I N S T R U M E N T S



CentriFlow®

# Material Test Report

Diced Apricots



CentriFlow®

Date Tested:	August 14, 2006	Temperature:	Ambient (78°F/25.6°C)
Technician:	Thomas Britt	Particle Size:	0.25" to 1.00"
Test Location:	Eastern Instruments	Flowability:	Average
CFM Model:	6" Type I CentriFlow®	Cohesiveness:	Slight
Meter Capacity:	6.75 ft³/min	Density (lb/ft³):	43 lbs/ft³
Feed System:	Belt Conveyor	Inhibit Setting:	0.200 Volts



Test #1	Mass Flow Rate = 5,300 lbs/hr				Percent of Volumetric Capacity = 29%		
Run #	Actual Weight	Metered Weight	Actual/Metered	Delta Weight	% Error		
1	9.11	9.10	1.002	-0.01	-0.15%		
2	8.95	8.96	0.999	0.01	0.08%		
3	8.72	8.73	0.999	0.01	0.11%		
4	8.86	8.86	1.000	0.00	-0.02%		
5	8.86	8.86	1.000	0.00	-0.02%		
Average:			1.000				
STD:			0.0010				
% STD:			0.10%				

**Additional Comments:** Tested with a 6" CentriFlow® Type I Meter in the Reverse Direction Flow Configuration. Run time was 6 seconds per batch.

### Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within  $\pm 0.25\%$  of reading when operating within  $\pm 10\%$  of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."