



E A S T E R N I N S T R U M E N T S



CentriFlow®

Material Test Report

Corn Flour



CentriFlow®

Date Tested:	June 18, 2000	Temperature:	Ambient (78°F/25.6°C)
Technician:	Alan Norman	Particle Size:	500 Microns
Test Location:	Eastern Instruments	Flowability:	Average
CFM Model:	6" Type II CentriFlow®	Cohesiveness:	Moderate
Meter Capacity:	6.75 ft ³ /min	Density (lb/ft ³):	31 lb/ft ³
Feed System:	Screw Conveyor	Inhibit Setting:	0.200 Volts



Test #1		Percent of Volumetric Capacity = 50%							
Run #	Actual Weight	Metered Weight	Actual/Metered	Delta Weight			% Error		
1	43.08	42.94	1.003	-0.140			-0.32%		
2	39.18	39.20	0.999	0.020			0.05%		
3	37.75	37.72	1.001	-0.030			-0.08%		
4	38.78	38.74	1.001	-0.040			-0.10%		
5	40.06	40.00	1.002	-0.060			-0.15%		
Average:			1.0012						
STD:			0.0014						
% STD:			0.14%						
Additional Comments: Tested using a 6" CentriFlow® Type II Meter equipped with Vibraweigh®. The run time was 20 seconds per batch.									

Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within $\pm 0.25\%$ of reading when operating within $\pm 10\%$ of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."