



E A S T E R N I N S T R U M E N T S



CentriFlow®

Material Test Report

Herb Seasoned Croutons (Large Cubes)



CentriFlow®

Date Tested:	October 8, 2007	Temperature:	Ambient (78°F/25.6°C)
Technician:	Scott Tupper	Particle Size:	3/4" x 3/4" - Fines
Test Location:	Eastern Instruments	Flowability:	Average
CFM Model:	12" Type I CentriFlow®	Cohesiveness:	None
Meter Capacity:	15 ft³/min	Density (lb/ft³):	9 lb/ft³
Feed System:	Vibratory Conveyor	Inhibit Setting:	0.200 Volts



Test #1	Mass Flow Rate = 3,600 lb/hr				Percent of Volumetric Capacity = 44%				
Run #	Actual Weight		Metered Weight		Actual/Metered		Delta Weight		% Error
1	8.04	8.04	8.04	8.04	1.000	0.000	0.000	0.00%	
2	8.04	8.02	8.02	8.02	1.002	-0.020	-0.25%	-0.25%	
3	8.04	8.01	8.01	8.01	1.004	-0.030	-0.37%	-0.37%	
4	8.04	7.98	7.98	7.98	1.008	-0.060	-0.75%	-0.75%	
5	8.04	8.03	8.03	8.03	1.001	-0.010	-0.12%	-0.12%	
Average:					1.003				
STD:					0.0029				
% STD:					0.29%				

Additional Comments: Tested using a 12" CentriFlow® Type I Meter in the Reverse Feed Flow Configuration, equipped with Vibraweigh®.

Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within $\pm 1.00\%$ of reading when operating within $\pm 10\%$ of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."