



EASTERN INSTRUMENTS



CentriFlow®


Material Test Report

Dry Corn Starch



CentriFlow®

Date Tested:	August 9, 2011	Temperature:	Ambient (78°F/25.6°C)
Technician:	James Seagraves	Particle Size:	Fine Powder
Test Location:	Eastern Instruments	Flowability:	Average
CFM Model:	6" Type II CentriFlow®	Cohesiveness:	Slight
Meter Capacity:	6.75 ft ³ /min	Density (lb/ft ³):	40-45 lbs/ft ³
Feed System:	Screw Conveyor	Inhibit Setting:	0.50%



Test #1	Mass Flow Rate = 6,000 - 8,000 lb/hr				Full Scale = 15,000 lb/hr	
Run #	Actual Weight	Metered Weight	Metered/Actual	Delta Weight	% Error	
1	24.00	24.04	0.9983	0.04	0.167%	
2	18.78	18.83	0.9976	0.04	0.240%	
3	16.76	16.77	0.9996	0.01	0.040%	
4	19.08	19.08	0.9998	0.00	0.017%	
5	20.72	20.74	0.9990	0.02	0.105%	
Average:			0.9989			
STD:			0.00091			
% STD:			0.09%			
Additional Comments: Tested with a 6" CentriFlow® Type II Meter equipped with VibraWeigh and a 56 Degree Diverter.						

Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within $\pm 0.25\%$ of reading when operating within $\pm 10\%$ of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."