



CentriFlow®

Material Test Report

Lime, Powdered



CentriFlow®

Date Tested:	August 5, 1999	Temperature:	Ambient (78°F/25.6°C)
Technician:	James Seagraves	Particle Size:	Under 0.001"
Test Location:	Eastern Instruments	Flowability:	Above Average
CFM Model:	6" Type II CentriFlow®	Cohesiveness:	Slight
Meter Capacity:	6.75 ft³/min	Density (lb/ft³):	50-55 lb/ft³
Feed System:	Screw Conveyor	Inhibit Setting:	0.200 Volts



Test #1		Percent of Volumetric Capacity = 75%						
Run #	Actual Weight	Metered Weight	Metered/Actual	Delta Weight	% Error			
1	22.92	22.95	1.001	0.030	0.13%			
2	22.70	22.75	1.002	0.050	0.22%			
3	22.56	22.55	1.000	-0.010	-0.04%			
4	22.44	22.45	1.000	0.010	0.04%			
5	22.88	22.85	0.999	-0.030	-0.13%			
Average:			1.000					
STD:			0.0014					
% STD:			0.14%					

Additional Comments: Tested using a 6" CentriFlow® Type II Meter equipped with Vibraweigh®. The run time was 7 seconds per batch.

Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within ±0.25% of reading when operating within ± 10% of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."