



E A S T E R N I N S T R U M E N T S



CentriFlow®

Material Test Report

Powdered Milk Replacer



CentriFlow®

Date Tested:	April 5, 1999	Temperature:	Ambient (78°F/25.6°C)
Technician:	James Seagraves	Particle Size:	Under 0.002"
Test Location:	Eastern Instruments	Flowability:	Average
CFM Model:	6" Type II CentriFlow®	Cohesiveness:	Slight
Meter Capacity:	6.75 ft ³ /min	Density (lb/ft ³):	35 lbs/ft ³
Feed System:	Screw Feeder	Inhibit Setting:	0.200 Volts



Picture Not Available

Test #1	Percent of Volumetric Capacity = 50%				
Run #	Actual Weight	Metered Weight	Metered/Actual	Delta Weight	% Error
1	44.16	44.13	0.999	-0.03	-0.07%
2	43.76	43.75	1.000	-0.01	-0.02%
3	43.26	43.29	1.001	0.03	0.07%
4	44.88	44.92	1.001	0.04	0.09%
5	43.96	44.03	1.002	0.07	0.16%
Average:			1.000		
STD:			0.0009		
% STD:			0.09%		
Additional Comments: Tested using a 6" CentriFlow® Type II Meter. The run times were 15 seconds per batch.					

Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within $\pm 0.25\%$ of reading when operating within $\pm 10\%$ of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."