



E A S T E R N I N S T R U M E N T S



CentriFlow®


Material Test Report

Molybdenum



CentriFlow®

Date Tested:	August 21, 2008	Temperature:	Ambient (78°F/25.6°C)
Technician:	Thomas Britt	Particle Size:	Powder
Test Location:	Eastern Instruments	Flowability:	Average
CFM Model:	3" Type II CentriFlow®	Cohesiveness:	Slight
Meter Capacity:	2.5 ft³/min	Density (lb/ft³):	80 lbs/ft³
Feed System:	Screw Feeder	Inhibit Setting:	0.200 Volts



Test #1	Mass Flow Rate = 6,000 lbs/hr				Percent of Volumetric Capacity = 36%				
Run #	Actual Weight	Metered Weight	Actual/Metered	Delta Weight	% Error				
1	21.76	21.77	1.000	0.01	0.05%				
2	22.30	22.25	1.002	-0.05	-0.22%				
3	22.28	22.26	1.001	-0.02	-0.09%				
4	22.20	22.20	1.000	0.00	0.00%				
5	22.76	22.74	1.001	-0.02	-0.09%				
Average:			1.001						
STD:			0.00104						
% STD:			0.10%						
Additional Comments: Tested with a 3" CentriFlow® Type II Meter equipped with a 56° Diverter and a SS One-Piece Pan Assembly.									

Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within $\pm 0.25\%$ of reading when operating within $\pm 10\%$ of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."