



CentriFlow®

Material Test Report

Dried Orange Chips



CentriFlow®

Date Tested:	August 12, 1999	Temperature:	Ambient (78°F/25.6°C)
Technician:	James Seagraves	Particle Size:	Dust to 1.00" x 0.125"
Test Location:	Eastern Instruments	Flowability:	High
CFM Model:	6" Type II CentriFlow®	Cohesiveness:	None
Meter Capacity:	6.75 ft³/min	Density (lb/ft³):	20 lb/ft³
Feed System:	Screw Conveyor	Inhibit Setting:	0.200 Volts



Test #1	Percent of Volumetric Capacity = 75%								
Run #	Actual Weight		Metered Weight		Metered/Actual		Delta Weight		% Error
1	21.44		21.45		1.000		0.010		0.05%
2	21.28		21.29		1.000		0.010		0.05%
3	21.28		21.29		1.000		0.010		0.05%
4	21.38		21.39		1.000		0.010		0.05%
5	21.42		21.44		1.001		0.020		0.09%
Average:					1.0006				
STD:					0.0002				
% STD:					0.02%				
Additional Comments: Tested using a 6" CentriFlow® Type II Meter. The run time was 17 seconds per batch.									

Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within ±0.25% of reading when operating within ± 10% of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."