



E A S T E R N I N S T R U M E N T S



CentriFlow®

# Material Test Report

## Sugar Coated Diced Pineapple



CentriFlow®

Date Tested:	August 14, 2006	Temperature:	Ambient (78°F/25.6°C)
Technician:	Thomas Britt	Particle Size:	0.25" to 1.50"
Test Location:	Eastern Instruments	Flowability:	Medium
CFM Model:	6" Type I CentriFlow®	Cohesiveness:	None
Meter Capacity:	6.75 ft <sup>3</sup> /min	Density (lb/ft <sup>3</sup> ):	42 lb/ft <sup>3</sup>
Feed System:	Belt Conveyor	Inhibit Setting:	0.200 Volts



Test #1	Mass Flow Rate = 6000 lb/hr				Percent of Volumetric Capacity = 30%			
Run #	Actual Weight		Metered Weight		Actual/Metered	Delta Weight		% Error
1	9.98	9.98	9.97	9.97	1.001	-0.010	-0.10%	
2	9.98	9.98	9.99	9.99	0.999	0.010	0.10%	
3	9.98	9.98	9.98	9.98	1.000	0.000	0.00%	
4	9.98	9.98	9.95	9.95	1.003	-0.030	-0.30%	
5	9.98	9.98	9.98	9.98	1.000	0.000	0.00%	
Average:					1.001			
STD:					0.0015			
% STD:					0.15%			
Additional Comments: Tested using a 6" CentriFlow® Type I Meter in the Reverse Direction Flow Configuration equipped with Vibraweigh®.								

### Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within  $\pm 0.50\%$  of reading when operating within  $\pm 10\%$  of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."