



E A S T E R N I N S T R U M E N T S



CentriFlow®

Material Test Report

Frozen Hashbrowns



CentriFlow®

Date Tested:	March 9, 2001	Temperature:	Frozen (16°F/-10°C)
Technician:	Alan Norman	Particle Size:	0.125" - 1.5"
Test Location:	Eastern Instruments	Flowability:	Average
CFM Model:	6" Type I CentriFlow®	Cohesiveness:	Slight
Meter Capacity:	6.75 ft ³ /min	Density (lb/ft ³):	15 - 20 lbs/ft ³
Feed System:	Vibratory Conveyor	Inhibit Setting:	0.200 Volts



Test #1	Percent of Volumetric Capacity = 25%								
Run #	Actual Weight		Metered Weight		Metered/Actual		Delta Weight		% Error
1	2.62		2.63		1.002		0.006		0.23%
2	2.63		2.63		1.000		0.000		0.00%
3	2.62		2.62		1.001		0.002		0.08%
4	2.62		2.62		1.001		0.002		0.08%
5	2.89		2.90		1.003		0.010		0.35%
Average:					1.0015				
STD:					0.0014				
% STD:					0.14%				

Additional Comments: Tested using a 6" CentriFlow® Type I Meter in the In-Line Flow Configuration. The run time was 10 seconds per batch.

Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within ±0.50% of reading when operating within ± 10% of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."