



E A S T E R N I N S T R U M E N T S



CentriFlow®

# Material Test Report

Titanium Ore



CentriFlow®

Date Tested:	January 27, 2005	Temperature:	Ambient (78°F/25.6°C)
Technician:	Scott Tupper	Particle Size:	Under 0.001"
Test Location:	Eastern Instruments	Flowability:	Above Average
CFM Model:	12" Type I CentriFlow®	Cohesiveness:	Slight
Meter Capacity:	15 ft³/min	Density (lb/ft³):	125 - 150 lbs/ft³
Feed System:	Vibratory Conveyor	Inhibit Setting:	0.200 Volts



**Picture Not  
Available**

Test #1		Percent of Volumetric Capacity = 75%						
Run #	Actual Weight	Metered Weight	Metered/Actual	Delta Weight			% Error	
1	30.10	30.09	1.000	-0.01			-0.03%	
2	30.08	30.13	1.002	0.05			0.17%	
3	34.96	35.03	1.002	0.07			0.20%	
4	34.94	35.03	1.003	0.09			0.26%	
5	34.94	35.03	1.003	0.09			0.26%	
Average:			1.002					
STD:			0.00120					
% STD:			0.12%					
Additional Comments: Tested with a 12" CentriFlow® Type I Meter in the In-Line Flow Configuration equipped with VibraWeigh®. Run time was 7								

### Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within  $\pm 0.25\%$  of reading when operating within  $\pm 10\%$  of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."