



EASTERN INSTRUMENTS



CentriFlow®

# Material Test Report

Wood Chips/Chunks



CentriFlow®

Date Tested:	January 6, 2010	Temperature:	Ambient (78°F/25.6°C)
Technician:	Ressie Cavanaugh	Particle Size:	0.5" x 0.5" - 1" x 6"
Test Location:	Eastern Instruments	Flowability:	Medium
CFM Model:	24" Type I CentriFlow® LDM Meter	Cohesiveness:	Medium
Meter Capacity:	120 ft <sup>3</sup> /min	Density (lb/ft <sup>3</sup> ):	30 lbs/ft <sup>3</sup>
Feed System:	Belt Conveyor	Inhibit Setting:	0.50%



Test #1	Mass Flow Rate = Various									
Run #	Actual Weight		Metered Weight		Metered/Actual		Delta Weight		% Error	
1	36.38		36.53		1.004		0.15		0.41%	
2	17.44		17.51		1.004		0.07		0.40%	
3	36.00		36.41		1.011		0.41		1.14%	
4	35.82		36.11		1.008		0.29		0.81%	
Average:					1.007					
STD:					0.00354					
% STD:					0.35%					

**Additional Comments:** Tested with a 24" CentriFlow® Type I Low Density Meter with a 10 degree tilt and a drop height of an additional 10" due to the added transition set at a 20 degree tilt. All flow surfaces were lined with UHMW.

### Accuracy Statement:

**"The CentriFlow® Meter will provide accuracy to within  $\pm 0.50\%$  -  $1.00\%$  of reading when operating within  $\pm 10\%$  of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."**