



E A S T E R N I N S T R U M E N T S



CentriFlow®

Material Test Report

Screened Wood Chips



CentriFlow®

Date Tested:	August 22, 2003	Temperature:	Ambient (78°F/25.6°C)
Technician:	Alan Norman	Particle Size:	Dust to 2"
Test Location:	Eastern Instruments	Flowability:	Average
CFM Model:	12" Type I CentriFlow®	Cohesiveness:	None
Meter Capacity:	15 ft ³ /min	Density (lb/ft ³):	15-20 lb/ft ³
Feed System:	Belt Conveyor	Inhibit Setting:	0.200 Volts



Test #1	Percent of Volumetric Capacity = 50%				
Run #	Actual Weight	Metered Weight	Metered/Actual	Delta Weight	% Error
1	7.60	7.57	0.996	-0.03	-0.39%
2	7.58	7.61	1.004	0.03	0.40%
3	7.56	7.57	1.001	0.01	0.13%
4	7.54	7.52	0.997	-0.02	-0.27%
5	7.52	7.48	0.995	-0.04	-0.53%
Average:			0.999		
STD:			0.00386		
% STD:			0.39%		
Additional Comments: Tested using a 12" CentriFlow® Type I Meter in the In-Line Flow Configuration. Run time was 15 seconds per batch.					

Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within $\pm 1.00\%$ of reading when operating within $\pm 10\%$ of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."