



E A S T E R N I N S T R U M E N T S



CentriFlow®


# Material Test Report

Whole Kernel Corn



CentriFlow®

Date Tested:	June 13, 2006	Temperature:	Ambient (78°F/25.6°C)
Technician:	Thomas Britt	Particle Size:	0.2" to 0.5"
Test Location:	Eastern Instruments	Flowability:	High
CFM Model:	6" Type II CentriFlow®	Cohesiveness:	None
Meter Capacity:	6.75 ft³/min	Density (lb/ft³):	55 lbs/ft³
Feed System:	Rotary Valve	Inhibit Setting:	0.200 Volts



## Test #1

Run #	Actual Weight	Metered Weight	Actual/Metered	Delta Weight	% Error
1	27.82	27.81	1.00036	-0.01	-0.04%
2	27.88	27.93	0.99821	0.05	0.18%
3	28.14	28.14	1.00000	0.00	0.00%
4	28.04	28.06	0.99929	0.02	0.07%
5	27.98	27.97	1.00036	-0.01	-0.04%

Average: 0.9996  
 STD: 0.0009  
 % STD: 0.09%

Additional Comments: Tested using a 6" CentriFlow® Type II Meter.

### Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within  $\pm 0.25\%$  of reading when operating within  $\pm 10\%$  of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."