



E A S T E R N I N S T R U M E N T S



CentriFlow®

# Material Test Report

Microsorb® - Oil Absorbent



CentriFlow®

Date Tested:	August 18, 2004	Temperature:	Ambient (78°F/25.6°C)
Technician:	Alan Norman	Particle Size:	30-200 mesh
Test Location:	Eastern Instruments	Flowability:	Above Average
CFM Model:	6" Type II CentriFlow®	Cohesiveness:	None
Meter Capacity:	6.75 ft <sup>3</sup> /min	Density (lb/ft <sup>3</sup> ):	20.5 lbs/ft <sup>3</sup>
Feed System:	Screw Feeder	Inhibit Setting:	0.200 Volts



**Picture Not Available**

Test #1		Percent of Volumetric Capacity = 50%						
Run #	Actual Weight	Metered Weight	Metered/Actual	Delta Weight	% Error			
1	8.02	8.06	1.004	0.04	0.44%			
2	9.80	9.80	1.000	0.00	0.03%			
3	9.70	9.77	1.008	0.07	0.75%			
4	9.72	9.72	1.000	0.00	0.04%			
5	9.57	9.62	1.005	0.05	0.47%			
Average:			1.003					
STD:			0.00311					
% STD:			0.31%					
Additional Comments: Tested using a 6" CentriFlow® Type II Meter equipped with VibraWeigh®. The run time was 15 seconds per batch.								

### Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within  $\pm 0.50\%$  of reading when operating within  $\pm 10\%$  of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."