



E A S T E R N I N S T R U M E N T S



CentriFlow®

# Material Test Report

Rubber Crumb



CentriFlow®

Date Tested:	December 13, 2007	Temperature:	Ambient (78°F/25.6°C)
Technician:	Brad Biamont	Particle Size:	Powder
Test Location:	Eastern Instruments	Flowability:	Average
CFM Model:	6" Type II CentriFlow®	Cohesiveness:	Slight
Meter Capacity:	6.75 ft <sup>3</sup> /min	Density (lb/ft <sup>3</sup> ):	25 lbs/ft <sup>3</sup>
Feed System:	Screw Feeder	Inhibit Setting:	0.200 Volts



Test #1	Mass Flow Rate = 16,500 lb/hr			Percent of Volumetric Capacity = 157%		
Run #	Actual Weight	Metered Weight	Actual/Metered	Delta Weight	% Error	
1	30.30	30.28	1.001	-0.02	-0.07%	
2	37.20	37.21	1.000	0.01	0.03%	
3	32.82	32.71	1.003	-0.11	-0.34%	
4	35.30	35.15	1.004	-0.15	-0.42%	
5	29.88	29.92	0.999	0.04	0.13%	
Average:			1.001			
STD:			0.00239			
% STD:			0.24%			
Additional Comments: Tested using a 6" CentriFlow® Type II Meter with NP3 coated Flow surfaces and VibraWeigh®						

### Accuracy Statement:

"The CentriFlow® Meter will provide accuracy to within  $\pm 0.75\%$  of reading when operating within  $\pm 10\%$  of the calibrated flow rate, as long as the flow rate is within the operational range of the meter."